

UC/CSU/IOU Energy Efficiency Partnership Monitoring-Based Commissioning (MBCx) Program

Karl Brown

**Deputy Director, California Institute for Energy and Environment
University of California Office of the President**

11 Jan 2006

Monitoring-Based Commissioning (MBCx)

UC/CSU/IOU Energy Efficiency Partnership

Outline

Background for Monitoring-Based Commissioning (MAP)

UC/CSU/IOU Energy Efficiency Partnership Program (JMN)

UC/CSU/IOU Monitoring-Based Commissioning Program

2004-05 Preliminary Case Studies

Cx Training and Education in UC/CSU/IOU Partnership

MBCx Team and Support Organizations

Monitoring-Based Commissioning (MBCx)

UC/CSU/IOU Energy Efficiency Partnership

Funding for:

Permanent Monitoring

Meters
Telemetry
Trending Software

Whole-Building Energy
Sub-System



Commissioning Consultants

Emphasis on Training for Campus Staff

In-House Staff (Limits)

Monitoring-Based Commissioning (MBCx)

UC/CSU/IOU Energy Efficiency Partnership

Key Program Features

Improved Operation of Existing Equipment/Systems
(as opposed to retrofit equipment upgrades)

Permanent Monitoring with Trending Capability

identifies dysfunction

assures verification and persistence of savings

Savings opportunities identified by combination of:

monitoring

test protocol-based methods

Benchmarking

Identification of Future Retrofit Projects

Best Practices Report for Future Planning

Monitoring-Based Commissioning (MBCx)

UC/CSU/IOU Energy Efficiency Partnership

Typical Targets

Reheat Systems

(minimize simultaneous heating and cooling)

Chilled/Hot Water Pump Systems

Variable Frequency Drives (VFD)

District Cooling Systems

(e.g. delta T issues)

Monitoring-Based Commissioning (MBCx)

UC/CSU/IOU Energy Efficiency Partnership

2004-05 Program Statistics (1 of 2):


25 Campuses

9 Plant Systems

40+ Buildings

over 5 million gross square feet

~ half laboratory or other energy intensive buildings



Monitoring-Based Commissioning (MBCx)

UC/CSU/IOU Energy Efficiency Partnership

2004-05 Program Statistics (2 of 2):

\$5 Million Total Funding

Project Size \$25k - \$350k

\$0.30 - \$1.75 per gsf for buildings

Savings Estimates (Conservative for Pilot Program)

1 MW peak demand

9,000,000 kWh per year

500,000 therms per year

2 -15% of current building or plant system use

Monitoring-Based Commissioning (MBCx) UC/CSU/IOU Energy Efficiency Partnership

Case Study #3 Library Building (original Cx in 1999)

Building Floor Area	215,000	gsf
Project Budget	\$83,500	
Monitoring Equipment	\$16,500	
Prep by Staff	\$14,000	
Commissioning Provider	\$46,500	
Staff Training for Ongoing Cx	\$ 6,500	
Savings Target	125,250	kWh/yr
	2	kW
	2,279	therms/yr

Monitoring-Based Commissioning (MBCx)

UC/CSU/IOU Energy Efficiency Partnership

Case Study #3: Library Building Benchmarking (215,000 gsf)

(Preliminary)	Electricity		Chilled Water	
	Annual Use	Maximum Power	Annual Use	Maximum
Historical	n/a	n/a	n/a	n/a
Revised	3,747,600 kWh/yr	730 kW	11 kton-hr/yr	74 tons
Index	17 kWh/yr/gsf*	3.4 W/gsf*	0.05 ton-hr/yr/gsf	0.3 tons/kgsf
Typical UC/CSU Non-Lab Building (climate normalized)	~11 kWh/yr/gsf*	~2.7 W/gsf*	n/a	~1.5 tons/kgsf

* Not Including Chilled Water Production
(Thermal/Gas Benchmark Data Under Review)

Monitoring-Based Commissioning (MBCx) UC/CSU/IOU Energy Efficiency Partnership

Case Study #3: Library Building

Initial Cx Measures:

- Identified primary/secondary CHW loop imbalance
(revealed by two days of warm weather monitoring)
- Adjusted controls to allow adequate CHW flow to coils
- Observed Fan Speed Reduction from 100% to 40%
(any corresponding increase in chiller load incurred at night)

Savings:

Overall Targets

125,250 kWh/yr
2 kW
2,279 therms/yr

Preliminary Savings Measurements

500,000 kWh/yr
100 kW
TBD therms/yr

(Project Budget: \$83,500)

Monitoring-Based Commissioning (MBCx) UC/CSU/IOU Energy Efficiency Partnership

Case Study #4: Lab Building Benchmarking (176,000 gsf)

(Preliminary)	Electricity (including chilled water production) Annual Use
Historical	9,113,440 kWh/yr
Revised	(in documentation)
Index	52 kWh/yr/gsf
Typical UC/CSU Lab Building (climate normalized)	~37 kWh/yr/gsf

Monitoring-Based Commissioning (MBCx) UC/CSU/IOU Energy Efficiency Partnership

Case Study #4: Lab Building Benchmarking (176,000 gsf)

(Preliminary)

Thermal / Natural Gas
Annual
Use

Historical

452,204 therms/year

Revised

(in documentation)

Index

~2.6 therms/year/gsf

Typical
UC/CSU
Lab Building
(climate
normalized)

~1.8 therms/year/gsf

Monitoring-Based Commissioning (MBCx) UC/CSU/IOU Energy Efficiency Partnership

Case Study #4: Lab Building

Building Floor Area (gsf)	176,000
Project Budget	\$270,000
Monitoring Equipment	\$130,000
Monitoring/EMCS Integration & Prep by Staff	\$ 75,000
Cx Provider	\$ 50,000
Staff Training for Ongoing Cx	\$ 15,000
Savings Target	409,260 kWh/yr
	47 kW
	13,100 th/yr

Monitoring-Based Commissioning (MBCx) UC/CSU/IOU Energy Efficiency Partnership

Case Study #4: Lab Building (176,000 gsf)

Initial Cx Measures:
(In documentation)

Savings:

Overall Targets

409,260 kWh/yr
47 kW
13,100 therms/yr

Savings Measurements

720,000 kWh/yr
117 kW
94,700 therms/yr

(Project Budget: \$270,000)

Monitoring-Based Commissioning (MBCx) UC/CSU/IOU Energy Efficiency Partnership

(Preliminary Summary)		Target Savings	Actual Savings		Project Budget
Case Study #1: Laboratory Building					
Electricity	(annual kWh) (kW*)	N/A**	N/A**		\$ 67,500
Gas	(annual therms)	13,292	43,000 (+224%)		
Case Study #2: Laboratory Building					
Electricity	(annual kWh) (kW*)	369,559	500,000 (+35%)		\$114,000
Gas	(annual therms)	3,000	TBD		
Case Study #3: Library					
Electricity	(annual kWh) (kW*)	125,250	450,000 (+259%)		\$ 83,500
Gas	(annual therms)	13,100	TBD		
Case Study #4: Laboratory Building					
Electricity	(annual kWh) (kW*)	409,260	720,000 (+76%)		\$270,000
Gas	(annual therms)	13,100	94,700 (+622%)		

* Annual peak kWh reported as average kW

** Savings target combined with district CHW project

UC/CSU/IOU Energy Efficiency Partnership

Training and Education Element

New Construction/Major Renovation
Tailored for UC/CSU Project Managers
(usually architects)

Commissioning Certification

Monitoring-Based Commissioning

Building Operator Certification Courses

Sustainability Conferences

Monitoring-Based Commissioning (MBCx)

UC/CSU/IOU Energy Efficiency Partnership

Monitoring-Based Commissioning (MBCx) Partner Team

Mark Bramfitt, Pacific Gas and Electric (PG&E, Co-chair)

Karl Brown, UCOP (Co-chair)

Ryan Stroup, PG&E (Lead for MBCx Training and Education)

Aaron Klemm, CSU

Paul Kylo & Tony Pierce, Southern California Edison

Randall Higa & Guy Hansen, Sempra

Keith Marchando, Sonoma State University

Jim Dewey, UC Santa Barbara

MBCx Team Consultants

Richard Sterrett, Alternative Energy Systems Consulting

Mike Anderson & Matt Sullivan, Newcomb Anderson McCormick

Ziyad Awad, Awad & Singer

Monitoring-Based Commissioning (MBCx)

UC/CSU/IOU Energy Efficiency Partnership Program

Support Organizations

Portland Energy Conservation, Inc (PECI)

Project Scoping Consultant to Campuses

MBCx Curriculum Development & Lead Instructor(s)

California Energy Commission

Public Interest Energy Research (PIER) Program

Technical Support (LBNL)

MBCx Case Studies and Needs Assessment

Monitoring (EIS) System Architecture

Benchmarking

MBCx Curriculum Development (PECI thru New Buildings Institute)

Commissioning Providers

Monitoring-Based Commissioning

UC/CSU/IOU Energy Efficiency Partnership

Contact: **Mike Anderson**
415-896-0300
Mike_Anderson@newcomb.cc

Karl Brown
510-287-3330
Karl.Brown@ucop.edu

Len Pettis
562-951-4122
LPettis@calstate.edu

Aaron Klemm
562-951-4121
AKlemm@calstate.edu

Monitoring-Based Commissioning

UC/CSU/IOU Energy Efficiency Partnership

MBCx Task Categories

Planning

Background Information

Pre-Investigation

Monitoring Installation/Upgrade

Investigation

Baseline

Diagnostics on Trended Data

Functional Performance Testing

Initial Implementation

Operational Changes, Maintenance and Repair

Document Remaining Opportunities incl. Retrofit

Handoff

Ongoing

Monitoring-Based Commissioning UC/CSU/IOU Energy Efficiency Partnership

Documents

MBCx Task List

Project-Specific Check List of Tasks for Cx Consultants:

Lead?

Support?

N/A


Findings Log

MBCx Plan

“M&V” Plan

Systems Manual

Summary Report



Monitoring-Based Commissioning

UC/CSU/IOU Energy Efficiency Partnership

Key UC Green Building and Clean Energy Policy Provisions

10% energy use reduction through energy efficiency measures by 2014

20% better than Title 24 for new buildings

LEED™ Existing Building (EB) approach under assessment—pilot projects encouraged

Partner with others to speed development of technologies that improve energy efficiency

Monitoring-Based Commissioning

UC/CSU/IOU Energy Efficiency Partnership

CSU Related Activities

2005/06 Commissioning Required MCO

Mechanical Review Board (MRB) Developing

Commissioning Guidelines New & Existing Buildings

Utility Infrastructure Guidelines

Controls Guidelines

Recommission 1 Building/Campus/Year

Monitoring-Based Commissioning

UC/CSU/IOU Energy Efficiency Partnership

New CSU Policy on Energy Efficiency & Sustainability

15% energy use reduction by 2010

15% better than Title 24 for new buildings

10% better than Title 24 for EB & R

2006/07 new buildings LEED Silver or CSU equivalent

2005/06 Savings by Design Strongly Encouraged

MRB Review Required

Brief History of Monitoring-Based Commissioning (MBCx)

1993	SMUD/PECI	1st National Conference on Building Cx
1994-1999	California Utilities/CIEE CEC/CIEE Texas A&M California Cx Collaborative	“Diagnostics for Cx & Operations” IMDS 160 Sansome Street IMDS 925 L Street ~ 100 Buildings
2000-03	SMUD/CIEE PIER UC Santa Barbara CSU Long Beach Central Florida State University UC Merced	IMDS 925 L Street Persistence of Retro-Cx Planning and Design
2004-05	UC/CSU/IOU Partnership PIER	CSU/UC Campuses

Monitoring-Based Commissioning (MBCx)

UC/CSU/IOU Energy Efficiency Partnership

Case Study #1: Lab Building (original Cx in 1996) plus District Chilled Water Pumping

	Lab Building	District System	Overall Project
Building Floor Area (gsf)	113,000	n/a	
Project Budget	\$ 67,500	\$161,500	\$239,000
Engineering		\$ 15,000	
Monitoring Equipment	\$ 10,000	\$ 89,000	
Prep by Staff	\$ 7,500	\$ 7,500	
Cx Provider	\$ 50,000	\$ 50,000	
Savings Target			1,241,310 kWh/yr 90 kW 13,292 th/yr

Monitoring-Based Commissioning (MBCx)

UC/CSU/IOU Energy Efficiency Partnership

Case Study #1: Lab Building Benchmarking (113,000 gsf)

(Preliminary)	Electricity Annual Use	Maximum Power	Chilled Water Annual Use	Maximum
Historical	2,417,000 kWh/yr*	n/a	n/a ton-hr/yr	n/a tons
Revised	n/a	364 kW*		
Index	21 kWh/yr/gsf*	3.2 W/gsf*		
Typical UC/CSU Lab Building (climate normalized)	~35 kWh/yr/gsf*	~5 W/gsf*		

* Not Including Chilled Water Production

Monitoring-Based Commissioning (MBCx) UC/CSU/IOU Energy Efficiency Partnership

Case Study #1: Lab Building Benchmarking (113,000 gsf)

(Preliminary)

Thermal / Natural Gas
Annual
Use

Historical

n/a

Revised

~135,000 therms/year

Index

~1.2 therms/year/gsf

Typical
UC/CSU
Lab Building
(climate
normalized)

~1.8 therms/year/gsf

Monitoring-Based Commissioning (MBCx) UC/CSU/IOU Energy Efficiency Partnership

Case Study #1: Lab Building (original Cx in 1996) plus District Chilled Water Pumping

Initial Lab Building Cx:

- 12 VAV Fume Hood Valves Re-Commissioned
- 53 CV Exhaust Valves Re-Commissioned
- 3 Valves Failed Fully Open
- 1 Valve Failed Fully Closed
- 1 Temperature Control Adjustment
- Minimum Air Change Rates Reduced to Code Levels

Savings:

Overall Targets	(Lab Only) Preliminary Savings Measurements
1,241,310 kWh/yr	150,000 kWh/yr
90 kW	17 kW
13,292 therms/yr	43,000 therms/yr

(Lab Only Project Budget: \$67,500)

Monitoring-Based Commissioning (MBCx) UC/CSU/IOU Energy Efficiency Partnership

Case Study #2: Lab Building

Building Floor Area (gsf)	100,800
Project Budget	\$114,140
Monitoring Equipment	\$ 52,780
Prep by Staff	\$ 7,500
Cx Provider	\$ 51,360
Staff Training for Ongoing Cx	\$ 2,500
Savings Target	369,559 kWh/yr
	27 kW
	3,000 th/yr

Monitoring-Based Commissioning (MBCx)

UC/CSU/IOU Energy Efficiency Partnership

Case Study #2: Lab Building Benchmarking (100,800 gsf)

(Preliminary)	Electricity		Chilled Water	
	Annual Use	Maximum Power	Annual Use	Maximum
Historical	7,391,185 kWh/yr*	1,101 kW*	182 kton-hr/yr	543 tons
Revised	n/a	n/a	n/a	n/a
Index	73 kWh/yr/gsf*	11 W/gsf*	1.8 ton-hr/yr/gsf	5 tons/kgsf
Typical UC/CSU Lab Building (climate normalized)	~35 kWh/yr/gsf*	~5.5 W/gsf*	n/a	~3 tons/kgsf

* Not Including Chilled Water Production
(Thermal/Gas Benchmark Data Under Review)

Monitoring-Based Commissioning (MBCx) UC/CSU/IOU Energy Efficiency Partnership

Case Study #2: Lab Building

Initial Cx Measures:
(In documentation)

Savings:

Overall Targets

369,559 kWh/yr

27 kW

3,000 therms/yr

Preliminary Savings Measurements

(Partial) 500,000 kWh/yr

TBD kW

TBD therms/yr

(Project Budget: \$114,100)